

Progressive Code A.N.	Product	Date
AN_10	MOSAIC	16/02/2016
Application	Industrial thermal processes	
Description	MOSAIC safety controller can be an ideal solution for safety control of all applications where burners are used or, in general, in industrial thermal processes. Example: ovens, dryers for ceramic or cereals, shrink-sleeve wrappers & spreading lines, etc..	

Request

The most common requests for this kind of applications are the following:

1. Flame monitoring, according to 13849-1 standard, must reach PL e safety level.
2. Gas and burning oil pressure control (PL d).
3. Post-purge monitoring of gas presence in pipes (PL d).
4. Combustive-air ventilation turn-off control (PL d).



Note: With regards to these type of applications, a key factor should be highlighted: there should be no confusion between the actual "burner" and the plant or thermal process in which the burner is used. Burners must comply with specific standards requiring analogic reading functions of air-gas mixture and many other relating logic functions. Instead, standard EN 746-2 regulates burner's applications defining the thermal process required safety levels and regulations applicable.

Mosaic safety controller cannot be used to control the actual burner as it requires analogical functions; nevertheless, Mosaic becomes an optimal solution to control the thermal process and plant safety functions as it's able to handle a number of sensors required by the EN 746-2 standard, such as:

- Flame extinction monitoring: flame-presence detector sensors are normally used (often optical, non-safety) instead of the required SIL3-type or 2x SIL2-type flame detectors. More commonly, certified integrated burner monitoring systems (BMS), including flame control, are used. The SIL3-type or the 2x SIL2-type digital signal generated by the BMS can be used as input.
- Gas pressure monitoring: pressure switches (SIL2-type, SIL3 not available).
- Pilot-flame temperature control: temperature detectors (SIL3).
- Gas pipes purging control: gas detector (SIL3 or SIL2).
- Air-vent fans monitoring: flow sensors (SIL2).
- Air/fuel ratio monitoring: pressure switches (SIL2).

Applications

As we can see below, Mosaic functional and safety characteristics allow usage in different industrial thermal processes, such as:

- Ovens
- Cereals vertical drying plants
- Ceramic dryers
- Textile dryers
- Air vein burner
- Shrink-sleeve wrappers (packaging system)




The block diagram shown below indicates the relationships between system's components. The diagram clearly shows where Mosaic safety controller can take action. Based on the input received from sensors and safety systems, Mosaic OSSDs acts on the combustion-gas and combusive-air nozzles, controlling and adjusting the combustion process.

Process control (a)

1. Control and instrumentation system / Operator control level
 - Process control level
 - Control level (local)
 - Control (non-fail-safe)
 - Tuning and adjustments
 - Monitoring
2. Protective systems
 - E-stop
 - Safety interlock
 - Purge and pipe monitoring
 - Tightness control
 - Automatic burner control unit
 - Flue gas venting
 - Air/fuel ratio
 - Flow and pressure detectors
 - High temperature limits

Heated system (b)

3. Fuel supply (gas)
4. Combustion air supply
5. Burner system and ignition device
6. Combustion chamber
7. Processing chamber
8. Flue gas system.



Block diagram showing equipment for industrial thermal process generally consisting of the following components:

- Processing chamber (7)
- Burner (5)
- Protective system (2)
- Control and instrumentation system (1)

Standard

These types of systems are regulated by European Standard **EN 746-2** - "Industrial thermoprocessing equipment safety requirements for combustion and fuel handling systems" May 2010. This Type C standard, as defined by EN ISO 12100-1, is part of the 8 standards forming the EN 746 safety standards "Industrial Thermoprocessing Equipment".

 **Note:** The EN 746-2 assumes that all equipments are not creating any potential explosive atmosphere and are located in a normally ventilated area.

EN 746-2 defines the requirements for the protective-and-safety systems of these devices:

- The protective-and-safety system is a group of devices, control units and safety circuits whose main purpose is the protection of the personnel, the plant and the environment.
- The protective-and-safety system includes all components required to carry out the safety function:
 - Sensors for monitoring safety-related parameters (e.g. flame temperature, air pressure, etc..);
 - Combustion-gas and combusive-air blocking devices (valves);
 - Combustion-chamber ventilation control and burner protection devices (e.g. temperature level monitoring);
- A protective-and-safety system is typically made up of sensors, control logics, actuator devices and a multi-channel system allowing communication between all elements. The required safety monitoring of the whole system can be performed by Mosaic.

The standard also defines the conditions that the protective-and-safety system should fulfill, indicating 4

possible scenarios as shown in the following table:

Condition	Device	Standard
Hardwired system in which all components comply with the relevant product standards as specified in 5.2 to 5.6	Automatic burner control systems	EN 298
	Valve testing systems	EN 1643
	Pressure sensing devices	EN 1854
	Automatic shut-off valves	EN 161
	Gas/Air ratio controls	EN 12067-2
Hardwired system with a combination of: <ul style="list-style-type: none"> components complying with the relevant product standards as specified in 5.2 to 5.6 components complying with defined SIL/PL level in accordance respectively with EN 62061 and EN ISO 13849-1 	Automatic burner control systems	EN 298
	Valve testing systems	EN 1643
	Pressure sensing devices	EN 1854
	Automatic shut-off valves	EN 161
	Gas/Air ratio controls	EN 12067-2
PLC based system with a combination of: <ul style="list-style-type: none"> components complying with the relevant product standards as specified in 5.2 to 5.6 components complying with defined SIL/PL level in accordance respectively with EN 62061 and EN ISO 13849-1 	Guarding functions (e.g. gas pressure, temperature) performed by components for which no relevant product standards are existing shall comply with at least: SIL 2 / PLd	IEC 62061 (SIL)
	Functions which will lead to immediate hazard in case of failure (e.g. flame detector device, ratio monitoring) performed by components for which no relevant product standards are existing shall comply with at least: SIL 3 / PL e	EN ISO 13849 (PL)
	Automatic burner control systems	EN 298
	Valve testing systems	EN 1543
	Pressure sensing devices	EN 1854
PLC based system in which all components comply with defined SIL 3 /PL e and with a defined SIL 3/PL e of hard and software.	Automatic shut-off valves	EN 161
	Gas/Air ratio controls	EN 12067-2
	Guarding functions (e.g. gas pressure, temperature) performed by components for which no relevant product standards are existing shall comply with at least: SIL 2 / PLd	IEC 62061 (SIL)
	Functions which will lead to immediate hazard in case of failure (e.g. flame detector device, ratio monitoring) performed by components for which no relevant product standards are existing shall comply with at least: SIL 3 / PL e	EN ISO 13849 (PL)
	Software for safety functions should be separate from other functions (e.g. control functions) the software for safety functions shall be designed in accordance with the requirements of EN ISO 13849 and EN 62061.	
PLC based system in which all components comply with defined SIL 3 /PL e and with a defined SIL 3/PL e of hard and software.	A PLC used for safety functions shall comply with EN ISO 13849-1 e EN 62061.	
	In this case EN ISO 13849-1 and EN 62061 shall be applied for the protective system in general	IEC 62061 (SIL)
		EN ISO 13849 (PL)

MOSAIC

MOSAIC

Execution

Mosaic safety controller can be an optimal solution for the safety system of industrial thermal processes (see table page 3, where "Mosaic" is indicated).

A typical safety plant for a traditional direct gas flame burner, controlled with one Mosaic master module (M1), includes:

- 2 inputs for gas pressure switches - dual-channel redundancy.
- 2 inputs for flame detector sensors - normally used optical, non-safety sensor, instead of the required SIL3-type or 2x SIL2-type flame detectors.
- 2 input for air flow pressure switches - dual-channel redundancy.
- 1 OSSD pair for gas - dual-channel safety output to stop fuel supply.
- 1 OSSD pair for comburent (air) - supply fans control.



Note: Some plants may opt for different burners mounted in parallel. In this scenario, a main valve for common gas supply is usually in place. Nevertheless, the Mosaic configuration described above is still valid.

In more complex scenarios, or when Mosaic is used also to manage other non-safety functions of the plant, one or more expansion modules could be required.

The table below indicates some manufacturers of industrial and civil boilers (in brackets the details of the Italian company where the application has been engineered and approved).

Company	Country	City	website
CMI Group	Belgium	Seraing	http://www.cmigroupe.com/en/
CCI Thermal Technologies Inc.	Canada	Orillia	http://www.chromalox.com/
Nanjing Nianda Furnace Science and Technology Co., Ltd	China	Nanjing	http://www.ndly.com.cn
PROTHERM (Gruppo Vailant)	Czech Republic	Praga	http://www.protherm.cz/kontakt/
AB&CO · TT BOILERS	Denmark	Copenhagen	http://ttboilers.com/steam-generator-boiler/
BABCOCK WANSON (Gruppo CNIM)	France	Nérac	www.babcock-wanson.fr
Bosch Industriekessel & Bosch KWK Systeme	Germany	Gunzenhausen	http://www.bosch-industrial.com/it/chi-siamo/aziende/bosch-industriekessel/
		Gunzenhausen	
		Bischofshofen	
Bosch KWK Systeme		Lollar	http://www.bosch-kwk.de/en/about-us/bosch-kwk-systeme-contact/
CERTUSS Dampfautomaten GmbH & Co. KG		Krefeld	http://www.certuss.com/
Linn High Therm GmbH		Eschenfelden	http://www.linn.de
Coperion GmbH (Headquarter)		Stuttgart	http://www.coperion.com/en/
Nabertherm GmbH (Headquarters)		Lilienthal	http://www.nabertherm.com/home/index/en
DORST Technologies		Kochel am See	http://www.dorst.de/de/home.html
PROODOS - INDUSTRIAL BOILERS	Greece	Thessaloniki	http://www.proodosboilers.com/index.php?hit=1
Ansaldo caldaie S.p.A. Boilers India Pvt. Ltd (Gruppo SOFINTER Spa)"	India	Chennai	http://www.ansaldoboiler.it/
Hokuriku Techno Co., Ltd	Japan	Imizu City Toyama	http://www.h-techno.com
BABCOCK WANSON (Gruppo CNIM)	Poland	Varsavia	www.babcock-wanson.pl
BABCOCK WANSON (Gruppo CNIM)	Portugal	Lisbona	www.babcock-wanson.pt

Company	Country	City	website
BABCOCK WANSON (Gruppo CNIM)	Spain	Erandio	www.babcock-wanson.es
ATTSU		Celra	http://www.attsu.com/es/
TRADE S.A. - C (Gruppo BIASI)		Madrid	http://www.tradesa.com/
ETE Europea Térmica Eléctrica, S.L.		Madrid	http://www.ete.es/
PIROBLOC S.A		Barcelona	http://www.pirobloc.com/
Industrial Furnaces Insertec, S.L.U.		Vizcaya	http://www.insertec.biz/es/
MAC Thermal & Process Industries S.A.		Bilbao	http://www.mac-tpi.com/
SOLO Swiss SA	Switzerland	Porrentruy	www.soloswiss.it/
DemirDöküm (Gruppo Vailant)	Turkey	Bilecik	http://www.demirdokum.com.tr/
BABCOCK WANSON (Gruppo CNIM)	U.K.	Hertfordshire	www.babcock-wanson.co.uk
Byworth Boilers		Keighley	http://byworth.co.uk/
Inductotherm Group		Droitwich	http://www.inductothermgroup.com
BABCOCK WANSON (Gruppo CNIM)	U.S.A. Missouri	Kansas City	www.babcockwanson-usa.com
Hurst Boiler & Welding Company, Inc.	U.S.A. Georgia	Coolidge	http://www.hurstboiler.com/
Cleaver-Brooks		Thomasville	http://www.cleaverbrooks.com/
Clayton Industries		City of industry	http://www.claytonindustries.com/index.aspx
Elan Technology		Midway	
TECFLAM	Italy	Cavriago (RE)	http://www.tecflam.it/it/homepage.html